



GTEC UPS MODEL:

LIBRA PRO - ARIES

Service Battery Alarm Code

SERVICE DOCUMENT

Enter Code 151515

Then enter code:

Service Battery alarm (322231 + set)

Display and set the number of months remaining to activate the alarm message "SERVICE BATTERY"

Note: from ver.27 rev.36 when it is active the alarm, it is displayed also the telephone number

that was set by the menu "MODEM dial n.=.." (keys 35744).

Months to service UPS: 50m 2d

Adjustment: 7=-,8=+

"50m 2d" : indicates that the alarm message will start after 50 months and 2 days from the present

moment in which the menu is displayed.

Service UPS alarm (152231 + set)

Display and set the number of months remaining to activate the alarm message "SERVICE UPS"

Note: from ver.27 rev.36 when it is active the alarm, it is displayed also the telephone number

that was set by the menu "MODEM dial n.=.." (keys 35744).

Months to service UPS: 50m 2d

Adjustment: 7=-,8=+

"50m 2d" : indicates that the alarm message will start after 50 months and 2 days from the present

moment in which the menu is displayed