




GTEC UPS MODEL:

# **SATURN - SIRIUS**


Autonomy battery test with  
UCOM GP Basic

**SERVICE DOCUMENT**


With the Service SW UCOMGP Basic, select Password and enter the password **batteryautonomy**.




Open the software “Battery Autonomy Test”, you insert the minutes for “Discharge time” and the “Additional rec” and push the “Start” button




You can decide the path where save the data files





Wait until the test will start






When the test reaches 1 minute", you can select "Print".






You choose the path where to save the picture



You will save a picture as below



The waveform will continue for another minute, because in the field "Additional rec =1 minute"

**Battery autonomy test**

Discharge Counter

Discharge time (min)  Start

Additional rec. (min)  Stop

00:01:00 Stop

Battery Voltage +

Battery Voltage -

Print

Close